

BLOCK WATER TESTING LABORATORY, ABOHAR


Hanuman garh Road in Water works Near Bye pass, Abohar
priyanka_gorde@thinksmartsoft.com

TEST REPORT						
Name & Address of Customer : Principal Imperial International School For Excellence, Khuian Sarwar			Customer Reference No.	No : 1091 Dated : 23/02/2024		
			Sample Submitted by			
			Date of Sample Receipt	22/02/2024		
			Analysis Starting Date	23/02/2024		
			Analysis completion Date	24/02/2024		
Discipline : Chemical Testing			Group: Water			
ULR No.:			Sample Type :	Water		
Test Report No.:	Abohar/2324/00202		Date of Issue :	29/02/2024		
Registration no.:	Abohar/REG2324/00666		Condition of Sample :	Sealed		
Collection Point:	Distribution Point(Near Bus stand,School,Gurudwara,etc)		Quantity/Type of Bottle:	1000 ml / Plastic Bottles		
Scheme/Source:	Not Mentioned(Not Mentioned)		Location/Depth :	Imperial International School for Excellence, Khuian Sarwar / NA		
Village :	Khuian Sarwar		Habitation :	Khuian Sarwar		
Block:	Khuian Sarwar		District :	Fazilka		
Latitude :	Not Mentioned		Longitude:	Not Mentioned		
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.40	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	210	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	1	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity	120	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness	176	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
9	Calcium	61	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	6	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride	124	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Mrs. Manju
Quality Manager
Authorized Signatory
For,Block Water Testing Laboratory
Abohar

BLOCK WATER TESTING LABORATORY, ABOHAR

Hanuman garh Road in Water works Near Bye pass, Abohar
priyanka_gorde@thinksmartsoft.com

To,

Principal
Imperial International School For Excellence, Khuian Sarwar


No.: Abohar/2324/00202 Dated : 29/02/2024

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 1091 Dated: 23/02/2024

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 22/02/2024. It is request to fill the attached feedback form and send it back to Block Water Testing Laboratory, Abohar

D/A : Test Report



Authorized Signatory
For, Block Water Testing Laboratory
Abohar